

Missouri
Department
of Transportation



Dan Niec, District Engineer

North Central District
902 North Missouri St.
P.O. Box 8
Macon, MO 63552
(660) 385-8246
Fax (660) 385-1707
Toll free 1-888 ASK MoDOT
<http://www.modot.mo.gov>

**ADDENDUM 002
REQUEST FOR QUOTES
REFURBISH AND REPAIR SALT BUILDINGS
RFQ NUMBER: D207-072-RE**

Bidders shall acknowledge receipt of Addendum 002 (two) by signing and including it with the original bid. The due date for receipt of bids remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

| | |
|---|---|
| Name and Title of Signer (Print or type) | Name and Title of Department Authority Betty Dwiggin Senior General Services Technician |
| Bidder Signature _____ | Department of Transportation  _____ |
| (Signature of person authorized to sign) | (Authorizing Signature) |
| Date Signed: | Date Signed May 5, 2007 |

NOTE: This signed addendum MUST be included with your response to the Request For Quote. If you have already mailed or delivered your quote, please sign, date and fax this form to 660-385-1707 before 1:00 PM CT May 09, 2007

Question: What kind of doors should be installed at the salt buildings located at Marshall and Sweet Springs?

Answer: Doors for both locations should be framed in center bay and side with insulated metal 6 ft double doors with wood jamb.